



Electrical Requirements

Electrical Requirements:

One, of the two power configurations, is are required, depending on which one is **SUPPLIED by the POWER UTILITY;**

Option A: If 208 volt, 3 phase electricity is supplied by the power utility, then a 60 amp, 4 Pole, 5 Wire, 3phY120/208V pin and sleeve receptacle is required. Typical part numbers for required outlet is HBL560R9W for unswitched or HBL560MI9W with a built in lockout.



or

Option B: If 240 volt, single phase electricity is supplied by the power utility, then a 100 amp, 3 pole, 4 wire, 125/250V pin and sleeve receptacle is required. Typical part number for required outlet is HBL4100R12W for unswitched.



PLEASE NOTE THAT THERE IS A DEDICATED NEUTRAL REQUIRED

If neither power configuration is available and a 25KVA generator is required, **a pigtail is available for use for a fee (see rate sheet).**

The Pigtail must be wired in the following format;

Pigtail		Panel
Green -----	to -----	ground
White -----	to -----	Neutral
Black -----	to -----	L1
Red -----	to -----	L2
Blue -----	to -----	L3 (omit if wiring to 240V/100amp single phase disconnect)

Initial _____ , Date: _____